



**PUMP STATION DESIGN DATA**

AVG. DAILY SEWAGE FLOW: \_\_\_ PEOPLE @ 105 G.C.D.    \_\_\_ G.P.D.

AVG. FLOW \_\_\_ G.P.D. / 1,440    \_\_\_ G.P.M.

DESIGN PUMPING RATE PER PUMP: 300% 3 X \_\_\_ G.P.M.    \_\_\_ G.P.M.

STATIC HEAD: \_\_\_ FEET

FORCE MAIN SIZE: \_\_\_ (M/TLS) \_\_\_ (IC= \_\_\_)    \_\_\_ FEET

DYNAMIC HEAD LOSS @ \_\_\_ G.P.M. (PUMPING RATE)    \_\_\_ FEET

TOTAL DYNAMIC HEAD (T.D.H.)    \_\_\_ FEET

\* DESIGN PER LOCAL CODE.

**PUMP STATION DATA**

TWO \_\_\_ HP (MIN.) PUMPS

CAPACITY (OPERATING POINT) \_\_\_ G.P.M. @ \_\_\_ T.D.H.

PUMP MODEL: \_\_\_ IMPELLER DIA: \_\_\_

DISCHARGE SIZE: \_\_\_

SOLIDS PASSING SIZE: \_\_\_

VOLTAGE: \_\_\_

PHASE: \_\_\_

THE INFORMATION ON THESE DRAWINGS OR WEB PAGES IS MADE AVAILABLE FOR YOUR USE. HOWEVER, YOU USE THE INFORMATION AT YOUR OWN RISK. WE BELIEVE THE INFORMATION TO BE CORRECT AND ACCURATE AT THE TIME OF ISSUE. ZOLLER COMPANY ASSUMES NO LIABILITY EXPRESSED OR IMPLIED, RESULTING FROM YOUR ACCESSING AND USING THIS INFORMATION, DUE TO CHANGES AND/OR DOWNLOAD PROBLEMS, IT IS YOUR RESPONSIBILITY AND YOU AGREE TO BE SOLELY RESPONSIBLE TO VERIFY THAT THE INFORMATION IS CORRECT AND ACCURATE FOR YOUR PURPOSES.

ZEPD0301